



Traralgon Laboratory
 5 Church Street
 Traralgon Vic 3844
 email: mwlmail@ghd.com.au
 web: www.ghd.com.au/ghdgeotechnics
 Tel: (03) 5136 5900
 Fax: (03) 5136 5999

Aggregate/Soil Test Report

Report No: TRA1800165

Issue No: 1

This report replaces all previous issues of report no 'TRA1800165'.

Client:

Gippsland Premium Quarries Pty Ltd
 PO Box 1
 Neerim Junction Vic 3832

Project:

QA Testing Sand - GPQ



Accredited for compliance with ISO / IEC 17025 - Testing

NATA Accredited
 Laboratory Number:
 4092

Approved Signatory: Rod Smith (Laboratory Manager)

Date of Issue: 8/02/2018

THIS DOCUMENT SHALL NOT BE REPRODUCED EXCEPT IN FULL

Sample Details

GHD Sample No TRA18-0122-03
Date Sampled 06/02/2018
Sampled By Sampled By Client
Location 160 Thurlows Rd, Shady Crk
Client Location Sample ID: 320 - 361 - A2 Filter
Soil Description Client Description:361 - A2 Filter Sand

Other Test Results

Description	Method	Result	Limits
Moisture Content (%)	AS 1289.2.1.1	3.9	


Particle Size Distribution

AS 1289.3.6.1

Drying by: Oven
Date Tested:

Note: Sample Washed

Sieve Size	% Passing	Limits
6.7mm	100	
4.75mm	99	
2.36mm	87	
1.18mm	56	
600µm	31	
425µm	23	
300µm	15	
150µm	5	
75µm	2	



Comments

N/A